



Agenda Item

File #: 24-2131

Requested Agenda Date:

9/24/2024

Requested Agenda Title:

Budget Adjustment: The Rampton Salt Palace Requests \$40,000 to Replace the Boiler Blowdown Steam Cooler Using Funds from the Replacement Project for the Condensate Line Between Abravanel Hall and the Salt Palace

Requested Agenda Item Description: Replace blow down steam cooler: Costs \$40K. Equipment has failed and requires that we blow down steam directly into the "pit". Equipment is dangerous to operate. We are moving the project forward and using operating funds but would like to utilize capital funds from the AH condensate line project.

Requested Action: Discussion - Vote Needed

Presenter(s) (with titles): Hoa Nguyen, Council Budget and Policy Analyst

Time Needed: Less than 5 MINS

Is this Item Time-Sensitive and/or Requesting a Time-Certain? No

Requesting Staff Member: Dan Hayes, SMG General Manager

Are Supporting Documents Needed for this Agenda Item Request? Yes