



Legislation Details (With Text)

File #: 21-1064 **Version:** 1 **Name:**
Type: Discussion Items **Status:** Passed
File created: 9/8/2021 **In control:** Council Work Session
On agenda: 9/14/2021 **Final action:** 9/14/2021
Title: Budget Adjustment: Facilities' Request to Transfer \$90,000 between Capital Projects from EH HVAC Phase II Project to the North and South Buildings Fire Alarm Upgrade

Sponsors:

Indexes:

Code sections:

Attachments: 1. Staff Report, 2. 23068 - FAC159C - CGC - No & So BLDGS Fire Alarm Upgrade

Date	Ver.	Action By	Action	Result
9/14/2021	1	Council Work Session	approved and forwarded	Pass
9/14/2021	1	County Council	ratified	Pass

Requested Agenda Date:

9/14/2021

Requested Agenda Title:

Budget Adjustment: Facilities' Request to Transfer \$90,000 between Capital Projects from EH HVAC Phase II Project to the North and South Buildings Fire Alarm Upgrade

Requested Agenda Item Description: Project FAC159C County Government Center North & South Buildings Fire Alarm upgrade additional funds request. It was discovered the existing conduits could not be used to pull wire for the alarms due to code requirements, new conduits need to be installed to accommodate the new wiring.

Requested Action: Discussion - Vote Needed

Presenter(s) (with titles): Brad Kendrick Budget and Policy Analyst

Time Needed: Less than 5 MINS

Is this Item Time-Sensitive and/or Requesting a Time-Certain? No

Requesting Staff Member: Rory Payne

Are Supporting Documents Needed for this Agenda Item Request? Yes

Please attach supporting documentation, including presentations, to the Legistar file.

Agenda item requests must be complete and submitted via Legistar Approval Sequence to the Council Administrative & Communications Coordinator by the Wednesday before the upcoming Tuesday meeting at

3:00 PM. Please note that some offices have earlier, internal Approval Sequence deadlines.

Items without necessary supporting documentation may be withheld from consideration for the desired meeting date.